

PWS #: 5700643
 Source Code: 5700643-001
 Source Name: Well 001
 Location: _____

Plainfield Elementary School
 20450 County Road 97
 Woodland, CA 95695

Month/Year: 01/2023

System Type: NTNC

Lab Samples	
MONTHLY TESTING	
<u>I</u> 100-1	Bac-T: P/A DST_003
QUARTERLY TESTING - 001_001	
100-2	Bac-T Sample: MPN
ANNUAL TESTING-001_001	
101-1	Nitrate (as N) - 05/2023
OTHER TESTING-001_001	
100	Bac-T Sample: OTHER
101-11	Primary Inorganics - 05/2025
<u>Circle</u>	Cyanide - Fluoride - Perchlorate
101-02	Nitrite (as N) - 05/2025
101-3	Primary Asbestos - 08/2026
101-22	Gross Alpha - 11/2026
101-5	VOC - 05/2025
101-6	SOC - 05/2025
101-23	1,2,3-Trichloropropane 11/2024
DIST. TRIANNUAL TESTING	
101-4	Lead & Copper (5 Ea)-08/25-DST_LCR
101-12	DBP -TTHM - 08/2023-DST_901
101-13	DBP - HAA5 - 08/2023-DST_901
Admin	
<u>J</u> 827	Document Processing Fee
825	Electronic Document Transfer Fee
831	RAA Report
829	electronic Annual Report
830	Annual Consumer Confidence Report
832	Lead and Copper Report
833	Back Flow Device Inspection/Cert.
	Sanitary Survey w/YCEH

7 Ph Start		Site Samples/Recordings	
7 pH	1/3	817	Site Service Fee
		753	Meter
			<u>3101260</u>
		753	Meter Prior
			<u>30977280</u>
		139	Chlorine Residual
			<u>.28</u>
		508	Sodium Hypochloriate (NSF 60)
			Domestic Meter
			<u>3474527</u>
			Domestic Meter Prior
			<u>3446427</u>
			Gallons Used
		19.5	CL ² Level In <u>16.5</u> CL2 Level Out <u>16.5</u>
		19.5	
pH	1-16	817	Site Service Fee
		753	Meter
			<u>31039405</u>
			Chlorine Residual
			<u>.23</u>
		508	Sodium Hypochloriate (NSF 60)
			Domestic Meter
			<u>3497425</u>
			CL ² Level In <u>14</u> CL2 Level Out <u>28.5</u>
pH	1-30	817	Site Service Fee
		753	Meter
			<u>31067300</u>
			Chlorine Residual
			<u>.82</u>
		508	Sodium Hypochloriate (NSF 60)
			Domestic Meter
			<u>3591703</u>
			CL ² Level In <u>26</u> CL2 Level Out <u>27</u>
			Suction Strainer
			Stenner Tube
			Stenner Injection
			Injector Check Valve
			<u>14.5 to .5</u>
			<u>29 to 1</u> CL2 Dosage

Site Weather Conditions:

Date: 1/3/23 Time of Day: 1000
 Weather (circle): Sunny rainy cloudy
 Wind: Direction N Speed 9
 Ambient temperature: 42

MAINTENANCE PERFORMED BY RUD JOHNSON, EAI
 D2#: 31624
 T2#: 26218

 SIGNATURE

COMMENTS

**NAPA-SOLANO-YOLO-MARIN-MENDOCINO
COUNTY PUBLIC HEALTH LABORATORY**

2201 COURAGE DRIVE, MS 9-200, FAIRFIELD, CA 94533
 PHONE: 707-784-4410 FAX: 707-423-1979
 DIRECTOR: BEATRIX KAPUSINSZKY, PHD, PHLD (ABB)
 CLIA # 05D0601176 ELAP # 2396



WATER REPORT

SUBMITTER: EAI

Environmental Aqua Inc. 896 Aldridge Rd Ste. D VACAVILLE, CA 95688 CONTACT: N/A PH: (707) 469-9576 FAX: (707) 469-9420	LOCATION: 20450 County Rd 97, Plainfield Elementary School C/O: 20450 County Rd 97 WOODLAND, CA 95695 USA COUNTY: Yolo PHONE:
--	---

LAB #: 23W0017 COLLECTED BY: Bud Johnson SAMPLING POINT: Staff Admin Kitchen Sink, Treated Well SAMPLE TYPE: Environmental, Water TEMPERATURE 2.4 C AT RECEIPT:	DATE COLLECTED: 1/3/2023 10:06 AM DATE RECEIVED: 1/3/2023 1:39 PM TREATED: Yes CHLORINE (PPM): 0.28 PH: 7
--	---

TEST REQUESTED

RESULTS

18 Hour Presence/Absence

PSC: 5700643_DST_003 Acct#: 155754D. Monthly Routine.

Total Coliform Presence	Absent
Escherichia coli Presence	Absent
Water Comment	Sample meets bacteriology standards for drinking water.
Method (Water)	SM 9223 B Colilert 18
call log	N/A

Plainfield Elementary School 5700643
 Service Provider: Environmental Aqua

DATE		Bac-T Sample			Annual		Bac-T Repeat			Mo. Gal. Total
		Mo. Staff Lounge	MPN Well 01 QTR	CL2 Residual	Nitrate Well 01	Nitrite Well 01			Daily Avg	
Jan-23		A		0.28					2903.9	90020
Feb-23									0.0	
Mar-23									0.0	
Apr-23									0.0	
May-23									0.0	
Jun-23									0.0	
Jul-23									0.0	
Aug-23									0.0	
Sep-23									0.0	
Oct-23									0.0	
Nov-23									0.0	
Dec-23									0.0	
								Annual	Total	90020

DATE		GALLON METER COUNT			MO. TOTAL	SYST. TOTAL
			Well 001			
01/30/23	STOP		31067300			
12/26/22	START		30977280			
MONTHLY TOTAL			90020	0		
TOTAL			31067300	0	0	
					90020	31067300

DATE	WELL 01 STATIC WATER LEVEL
Jan-23	86'
Feb-23	
Mar-23	
Apr-23	
May-23	
Jun-23	
Jul-23	
Aug-23	
Sep-23	
Oct-23	
Nov-23	
Dec-23	

Plainfield Elementary School

Plainfield Elementary School -5700643 - January 2023 CL2 Residual Rpt

Created at: 2023-02-08 03:09:12

Date Range: 2023-01-01 00:00:00 - 2023-02-01 00:00:00

Date	CL2 Residual
1/1/2023	0.26
1/2/2023	0.29
1/3/2023	0.29
1/4/2023	0.30
1/5/2023	0.29
1/6/2023	0.29
1/7/2023	0.31
1/8/2023	0.32
1/9/2023	0.31
1/10/2023	0.32
1/11/2023	0.32
1/12/2023	0.30
1/13/2023	0.30
1/14/2023	0.30
1/15/2023	0.27
1/16/2023	0.26
1/17/2023	0.33
1/18/2023	0.65
1/19/2023	0.91
1/20/2023	1.06
1/21/2023	1.12
1/22/2023	1.09
1/23/2023	1.06
1/24/2023	1.06
1/25/2023	1.05
1/26/2023	1.03
1/27/2023	0.99
1/28/2023	0.96
1/29/2023	0.91
1/30/2023	0.85
1/31/2023	0.82
TOTAL	18.62
DAILY AVG.	0.60