

PWS #: 5700643
 Source Code: 5700643-001
 Source Name: Well 001
 Location: _____

Plainfield Elementary School
 20450 County Road 97
 Woodland, CA 95695

Month/Year: 02/2023
 System Type: NTNC

Lab Samples	
MONTHLY TESTING	
<u>1</u> 100-1	Bac-T: P/A DST_003
QUARTERLY TESTING - 001_001	
<u>1</u> 100-2	Bac-T Sample: MPN
ANNUAL TESTING-001_001	
<u> </u> 101-1	Nitrate (as N) - <u>05/2023</u>
OTHER TESTING-001_001	
<u> </u> 100	Bac-T Sample: OTHER
<u> </u> 101-11	Primary Inorganics - <u>05/2025</u>
<u> </u> Circle	Cyanide - Fluoride - Perchlorate
<u> </u> 101-02	Nitrite (as N) - <u>05/2025</u>
<u> </u> 101-3	Primary Asbestos - <u>08/2026</u>
<u> </u> 101-22	Gross Alpha - <u>11/2026</u>
<u> </u> 101-5	VOC - <u>05/2025</u>
<u> </u> 101-6	SOC - <u>05/2025</u>
<u> </u> 101-23	1,2,3-Trichloropropane <u>11/2024</u>
DIST. TRIANNUAL TESTING	
<u> </u> 101-4	Lead & Copper (5 Ea)- <u>08/25-DST_LCR</u>
<u> </u> 101-12	DBP -TTHM - <u>08/2023-DST_901</u>
<u> </u> 101-13	DBP - HAA5 - <u>08/2023-DST_901</u>
Admin	
<u>2</u> 827	Document Processing Fee
<u> </u> 825	Electronic Document Transfer Fee
<u> </u> 831	RAA Report
<u> </u> 829	electronic Annual Report
<u> </u> 830	Annual Consumer Confidence Report
<u> </u> 832	Lead and Copper Report
<u> </u> 833	Back Flow Device Inspection/Cert.
<u> </u> <u> </u>	Sanitary Survey w/YCEH

7 Ph Start		Site Samples/Recordings	
<u>7</u> pH	<u>2/14</u>	817	Site Service Fee
		753	Meter
		753	Meter Prior <u>31067300</u>
		<u>.82</u>	Chlorine Residual
		508	Sodium Hypochloriate (NSF 60)
			Domestic Meter
			Domestic Meter Prior
			Gallons Used
		<u>26/27</u>	CL ² Level In <u>25</u> CL2 Level Out <u>25</u>
		817	Site Service Fee
pH	<u>2/27</u>	753	Meter
			Chlorine Residual
		508	Sodium Hypochloriate (NSF 60)
			Domestic Meter
			CL ² Level In <u>23</u> CL2 Level Out <u>23</u>
		817	Site Service Fee
pH		753	Meter
			Chlorine Residual
		508	Sodium Hypochloriate (NSF 60)
			Domestic Meter
			CL ² Level In _____ CL2 Level Out _____
			Suction Strainer
			Stenner Tube
			Stenner Injection
			Injector Check Valve
		<u>14.5 to .5</u>	
		<u>29 to 1</u>	CL2 Dosage

Site Weather Conditions:

Date: 2/14/23 Time of Day: 0915
 Weather (circle): Sunny rainy cloudy
 Wind: Direction NW Speed 16
 Ambient temperature: 47

MAINTENANCE PERFORMED BY BUD JOHNSON, EAI
 D2#: 31624
 T2#: 26218

 SIGNATURE

COMMENTS

**NAPA-SOLANO-YOLO-MARIN-MENDOCINO
COUNTY PUBLIC HEALTH LABORATORY**

2201 COURAGE DRIVE, MS 9-200, FAIRFIELD, CA 94533
 PHONE: 707-784-4410 FAX: 707-423-1979
 DIRECTOR: BEATRIX KAPUSINSZKY, PHD, PHLD (ABB)
 CLIA # 05D0601176 ELAP # 2396



WATER REPORT

SUBMITTER: EAI

Environmental Aqua Inc. 896 Aldridge Rd Stc. D VACAVILLE, CA 95688 CONTACT: N/A PH: (707) 469-9576 FAX: (707) 469-9420	LOCATION: 20450 County Rd 97, Plainfield Elementary School C/O: 20450 County Rd 97 WOODLAND, CA 95695 COUNTY: PHONE:
--	--

LAB #: 23W0256 COLLECTED BY: Bud Johnson SAMPLING POINT: Staff Admin. Kitchen Sink; Treated Well SAMPLE TYPE: Environmental, Water TEMPERATURE 4.9 C AT RECEIPT:	DATE COLLECTED: 2/14/2023 9:36 AM DATE RECEIVED: 2/14/2023 2:14 PM TREATED: Yes CHLORINE (PPM): 0.53 PH: 7
---	--

TEST REQUESTED

RESULTS

24 Hour Presence/Absence

PSC: 5700643_DST)003; Monthly Routine

Total Coliform Presence	Absent
Escherichia coli Presence	Absent
Water Comment	Sample meets bacteriology standards for drinking water.
Method (Water)	SM 9223 B Colilert
call log	N/A

**NAPA-SOLANO-YOLO-MARIN-MENDOCINO
COUNTY PUBLIC HEALTH LABORATORY**

2201 COURAGE DRIVE, MS 9-200, FAIRFIELD, CA 94533
 PHONE: 707-784-4410 FAX: 707-423-1979
 DIRECTOR: BEATRIX KAPUSINSZKY, PHD, PHLD (ABB)
 CLIA # 05D0601176 ELAP # 2396



WATER REPORT

SUBMITTER: EAI

Environmental Aqua Inc. 896 Aldridge Rd Ste. D VACAVILLE, CA 95688 CONTACT: N/A PH: (707) 469-9576 FAX: (707) 469-9420	LOCATION: 20450 County Rd 97, Plainfield Elementary School C/O: 20450 County Rd 97 WOODLAND, CA 95695 COUNTY: Yolo PHONE:
--	---

LAB #: 23W0242 COLLECTED BY: Bud Johnson SAMPLING POINT: well 01, raw well SAMPLE TYPE: Environmental, Water TEMPERATURE 4.9 C AT RECEIPT:	DATE COLLECTED: 2/14/2023 9:15 AM DATE RECEIVED: 2/14/2023 2:16 PM TREATED: CHLORINE (PPM): 0 PH: 7
---	---

<u>TEST REQUESTED</u>	<u>RESULTS</u>	<u>UNITS</u>
1:1 Colilert Quantitray (18h) PSC: 5700643_001_001, quarterly routine		
Total Coliform	<1	MPN per 100 mL of water
Escherichia coli	<1	MPN per 100 mL of water
Method (Water)	SM 9223 B Colilert 18	
call log	N/A	

DATE		Bac-T Sample			Annual		Bac-T Repeat			Mo. Gal. Total
		Mo. Staff Lounge	MPN Well 01 QTR	CL2 Residual	Nitrate Well 01	Nitrite Well 01			Daily Avg	
Jan-23		A		0.28					2903.9	90020
Feb-23		A	A	0.53					1999.1	55975
Mar-23									0.0	
Apr-23									0.0	
May-23									0.0	
Jun-23									0.0	
Jul-23									0.0	
Aug-23									0.0	
Sep-23									0.0	
Oct-23									0.0	
Nov-23									0.0	
Dec-23									0.0	
								Annual	Total	145995

DATE		GALLON METER COUNT			MO. TOTAL	SYST. TOTAL
			Well 001			
02/27/23	STOP		31123275			
01/30/23	START		31067300			
MONTHLY TOTAL			55975	0		
TOTAL			31123275	0	0	
					55975	31123275

DATE	WELL 01 STATIC WATER LEVEL
Jan-23	86'
Feb-23	88'
Mar-23	
Apr-23	
May-23	
Jun-23	
Jul-23	
Aug-23	
Sep-23	
Oct-23	
Nov-23	
Dec-23	

Plainfield Elementary School

Plainfield Elementary School -5700643 - February 2023 CL2 Residual Rpt

Created at: 2023-03-08 21:23:27

Date Range: 2023-02-01 00:00:00 - 2023-03-01 00:00:00

Date	CL2 Residual
2/1/2023	0.82
2/2/2023	0.79
2/3/2023	0.78
2/4/2023	0.76
2/5/2023	0.72
2/6/2023	0.68
2/7/2023	0.71
2/8/2023	0.69
2/9/2023	0.64
2/10/2023	0.64
2/11/2023	0.61
2/12/2023	0.57
2/13/2023	0.54
2/14/2023	0.52
2/15/2023	0.54
2/16/2023	0.54
2/17/2023	0.60
2/18/2023	0.53
2/19/2023	0.50
2/20/2023	0.47
2/21/2023	0.46
2/22/2023	0.46
2/23/2023	0.47
2/24/2023	0.47
2/25/2023	0.45
2/26/2023	0.43
2/27/2023	0.40
2/28/2023	0.41
TOTAL	16.20
DAILY AVG.	0.58